MISSISSIPPI STATE DEPARTMENT OF HEALTH

(NOT PREFERRED)

2020 CERTIFICATION

Consumer Confidence Report (CCR)

10WM OF Crosby		
Public Water Sys	tem Name	
0030002		
List PWS ID #s for all Community Water	er Systems included in this CCR	
The Federal Safe Drinking Water Act (SDWA) requires each Community Confidence Report (CCR) to its customers each year. Depending on the pothe customers, published in a newspaper of local circulation, or provided procedures when distributing the CCR.	pulation served by the PWS, this CCR must be	e mailed or delivered to
CCR DISTRIBUTION (Chec.	k all boxes that apply.)	
INDIRECT DELIVERY METHODS (Attach copy of publication, water	bill or other)	DATE ISSUED
□ Advertisement in local paper (Attach copy of advertisement)		
□ On water bills (Attach copy of bill)		
□ Email message (Email the message to the address below)		
□ Other		
DIRECT DELIVERY METHOD (Attach copy of publication, water bill	or other)	DATE ISSUED
□ Distributed via U. S. Postal Mail		
□ Distributed via E-Mail as a URL (Provide Direct URL):		
□ Distributed via E-Mail as an attachment		
□ Distributed via E-Mail as text within the body of email message		
□ Published in local newspaper (attach copy of published CCR or pro	oof of publication)	
Posted in public places (attach list of locations) Crossy Town □ Posted online at the following address (Provide Direct URL):	Hell Crocky Post Office	6-1-2021
□ Posted online at the following address (Provide Direct URL):	Crosty Quick Stop	
I hereby certify that the CCR has been distributed to the customers above and that I used distribution methods allowed by the SDWA. I and correct and is consistent with the water quality monitoring data Water Supply.	of this public water system in the form a further certify that the information include	ed in this CCR is true
SUBMISSION OPTIONS (Se	lect one method ONLY)	20.0
You must email, fax (not preferred), or mail a cop	•	SDH.
Mail: (U.S. Postal Service)	Email: water.reports@msdh.ms.gov	

Fax: (601) 576-7800

MSDH, Bureau of Public Water Supply

P.O. Box 1700

Jackson, MS 39215

2020 Annual Drinking Water Quality Report Town of Crosby PWS#: 0030002 May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Crosby have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact William Hall at 601.730.8230. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:00 PM at the Crosby Town Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST RES	SULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Inorganic	Contam	inants				11		
10, Barium	N	2020	.0803	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.105	No Range	ppm	4	4	Erosion of natural deposits; wate additive which promotes strong teeth; discharge from fertilizer and aluminum factories

17. Lead	N	2018/20	1		0	p	pb		0 A	L=15	Corrosion of household plumbing systems, erosion of natural deposits	
Sodium	N	2019*	1500	00	No Range	Р	PB		0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.	
Volatile Or	ganio	Contam	inant	S								
76. Xylenes	N	2020	.001	048	No Range		ppm		10	10	Discharge from petroleum factories; discharge from chemical factories	
Disinfection	n By-	Products										
81. HAA5	N	2017*	5	No	Range	ppb		0	6		By-Product of drinking water disinfection.	
82. TTHM [Total trihalomethanes]	N	2017*	4.2	No	Range	ppb		0	{		By-product of drinking water chlorination.	
Chlorine	N	2020	2.1	1.6	-2.4	mg/l		0	MDRL =		Vater additive used to control nicrobes	

^{*} Most recent sample. No sample required for 2020.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing for. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers, EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Town of Crosby works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Town of Crosby # 0030002

The CCR was posted at the

1. Crosby Town Hall

2. Crosby Post Office

3. Crosby Quick Stop